

Declaration of Performance according to Regulation (EU) 305/2011

No.: LE20050765/3



- product S25 GO-Line
- intended use space heating in residential buildings (slow heat release appliance)
- trade mark Camina & Schmid Feuerdesign und Technik GmbH & Co. KG
Gewerbepark 18 | 49143 D-Bissendorf
info@camina-schmid.de | www.camina-schmid.de
- authorized representative -
- system of assessment and verification of constancy of performance of the construction product system 3
- The notified laboratory DBI-Gastechnologisches Institut gGmbH Freiberg
D-09599 Freiberg – notified body number: 1721
performed of the product type on the basis of type testing under system 3.
report DBI F 20/05/0765
- declaration of performance

Harmonized technical specification	EN 15250:2007
essential characteristics	performance
fire safety	pass
reaction to fire	A1
minimum safety distance to combustible material (applies only to components made of combustible building materials with a heat transfer resistance $\leq 1.2 \text{ m}^2\text{K/W}$)	radiation area 1000 mm ceiling 410 mm floor 0 mm rear - mm sides 100 mm
risk of burning fuel falling out	pass
cleanability	pass
emission of combustion products (log of wood)	CO 846,9 mg/Nm ³ 0,068 %
surface temperature	pass
electrical safety	not applicable
release of dangerous substance	NPD
max. operation pressure	not applicable
flue gas outlet temperature at nominal heat output (log of wood)	201 °C
mechanical resistance (to carry a chimney/flue)	NPD
thermal output / efficiency	pass
discharge time	100% 3,2 h 50% 4,7 h 25% 8,2 h
total heat output	108000 KJ
efficiency (log of wood)	85,4 %

- The performance of the product is in conformity with the declared performance in point 7.
This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 3.

Signed on behalf of the manufacturer

Colin Rokossa | Managing Director
Bissendorf, 11.01.2023

02/2023

product

S25 GO-Line

test report	DBI F 20/05/0765		
fuel	log of wood		
triple value for nominal heat output (closed operation)			
flue gas mass flow	15,85 g/s		
flue gas temperature	201 °C		
required draught	12 Pa		
emission values (related to 13% O2) and efficiency at nominal heat output (closed operation)			
CO	846,9 mg/Nm ³	530,3 mg/MJ	0,068 %
PM	29,9 mg/Nm ³	18,8 mg/MJ	
NOx	114,4 mg/Nm ³	71,6 mg/MJ	
OGC	53,4 mg/Nm ³	36,0 mg/MJ	
efficiency	85,4 %		
Multiple chimney connections possible with closed fire chambers! Please note the installation and operating instructions!			